

ADDENDUM NUMBER THREE

June 2, 2023

**GOLETA UNION SCHOOL DISTRICT
CENTRAL KITCHEN MODERNIZATION**
401 NORTH FAIRVIEW AVE
GOLETA, CA 93117

Issued By:
KRUGER BENSEN ZIEMER ARCHITECTS, INC.
30 West Arrellaga Street
Santa Barbara, CA 93101

To all bidders submitting proposal(s) for the captioned project: this Addendum is hereby made part of the Contract Documents to the same extent as though it was originally included therein and takes precedence over the original documents and any previous addenda.

Acknowledge receipt of the Addendum on Form of Proposal

A. PROJECT MANUAL

ITEM NO. 1: Clarification to Specification Section 105123 – Solid Phenolic Lockers

Change Paragraph 2.2, A. to read: "Basis-of-Design Product Subject to compliance with requirements, provide "**Essentials Collection**" Phenolic Lockers by Hollman, Inc. 1825 W. Walnut Hill Lane, Irving, Texas, or equal acceptable to Architect."

A. Omit Paragraph 2.2, J:

"Continuously Sloping Tops: Solid phenolic, 1/2-inch-thick panel that matches door faces for installation over lockers with separate flat tops. Fabricate tops in lengths as long as practical, without visible fasteners at splice locations. Provide fasteners, supports, and closures, as follows:

1. Closures: Vertical-end type.
2. Sloping-top corner fillers, mitered."

B. CLARIFICATIONS

NO CLARIFICATIONS IN THIS ADDENDUM

C. DRAWINGS

ITEM NO. 1: Detail 6/A-900:

Change the base height from 6-inches to 4-inches and omit the sloped top.

D. ATTACHMENTS

NO ATTACHMENTS IN THIS ADDENDUM

END OF ADDENDUM NUMBER THREE