



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

**Test Address:**

GOLETA UNION SCHOOL DISTRICT  
5669 HOLLISTER AVE  
GOLETA, CA 93117

5465 QUEEN ANN LN  
SANTA BARBARA, CA 93111

Email: jwalker@goleta.k12.ca.us  
Phone: (805) 681-1231

Sample Date: October 5, 2017  
Date Received: October 11, 2017  
Analysis Date: October 16, 2017  
Report Date: October 16, 2017  
Sample Location: Room Ka-1

Test / COC #: 1078068  
Sample ID: 1078068-1

## CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	2.1 ppb	0 to 15 ppb	Pass

BDL = Below detection limit; cfu = colony forming units; mg/L = milligrams per liter; ntu = nephelometric turbidity units  
pH = acidity/alkalinity units; ppm = parts per million; ppb = parts per billion; µS/cm = microSiemens per centimeter  
U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.  
DET = Analyte detected; ND = Analyte not detected at or above the detection limit; NR = Not reported; dry = Sample results reported on a dry weight basis.  
RPT = Relative percent difference; V = Indicates that the analyte was detected in both the sample and the associated method blank.  
I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.  
Z = too many colonies were present for accurate counting

**CONCLUSION: PASS**

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

**Test Address:**

GOLETA UNION SCHOOL DISTRICT  
5669 HOLLISTER AVE  
GOLETA, CA 93117

5465 QUEEN ANN LN  
SANTA BARBARA, CA 93111

**Email:** jwalker@goleta.k12.ca.us  
**Phone:** (805) 681-1231

**Sample Date:** October 5, 2017  
**Date Received:** October 11, 2017  
**Analysis Date:** October 16, 2017  
**Report Date:** October 16, 2017  
**Sample Location:** Room Ka-2

**Test / COC #:** 1078068  
**Sample ID:** 1078068-2

## CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	17.3 ppb	0 to 15 ppb	*** FAIL ***

**BDL** = Below detection limit; **cfu** = colony forming units; **mg/L** = milligrams per liter; **ntu** = nephelometric turbidity units  
**pH** = acidity/alkalinity units; **ppm** = parts per million; **ppb** = parts per billion; **µS/cm** = microSiemens per centimeter  
**U** = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.  
**DET** = Analyte detected; **ND** = Analyte not detected at or above the detection limit; **NR** = Not reported; **dry** = Sample results reported on a dry weight basis.  
**RPT** = Relative percent difference; **V** = Indicates that the analyte was detected in both the sample and the associated method blank.  
**I** = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.  
**Z** = too many colonies were present for accurate counting

**CONCLUSION: \*\*\* FAIL \*\*\***

Some or all of the tested parameters do not meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels (MCLs) for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

  
 \_\_\_\_\_  
 Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

**Test Address:**

GOLETA UNION SCHOOL DISTRICT  
5669 HOLLISTER AVE  
GOLETA, CA 93117

5465 QUEEN ANN LN  
SANTA BARBARA, CA 93111

**Email:** jwalker@goleta.k12.ca.us  
**Phone:** (805) 681-1231

**Sample Date:** October 5, 2017  
**Date Received:** October 11, 2017  
**Analysis Date:** October 16, 2017  
**Report Date:** October 16, 2017  
**Sample Location:** Room Kb-1

**Test / COC #:** 1078068  
**Sample ID:** 1078068-3

## CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	35.3 ppb	0 to 15 ppb	*** FAIL ***

BDL = Below detection limit; cfu = colony forming units; mg/L = milligrams per liter; ntu = nephelometric turbidity units  
 pH = acidity/alkalinity units; ppm = parts per million; ppb = parts per billion; µS/cm = microSiemens per centimeter  
 U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.  
 DET = Analyte detected; ND = Analyte not detected at or above the detection limit; NR = Not reported; dry = Sample results reported on a dry weight basis.  
 RPT = Relative percent difference; V = Indicates that the analyte was detected in both the sample and the associated method blank.  
 I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.  
 Z = too many colonies were present for accurate counting

**CONCLUSION: \*\*\* FAIL \*\*\***

Some or all of the tested parameters do not meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels (MCLs) for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

  
 \_\_\_\_\_  
 Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

**Test Address:**

GOLETA UNION SCHOOL DISTRICT  
5669 HOLLISTER AVE  
GOLETA, CA 93117

5465 QUEEN ANN LN  
SANTA BARBARA, CA 93111

**Email:** jwalker@goleta.k12.ca.us  
**Phone:** (805) 681-1231

**Sample Date:** October 5, 2017  
**Date Received:** October 11, 2017  
**Analysis Date:** October 16, 2017  
**Report Date:** October 16, 2017  
**Sample Location:** Room Kb-2

**Test / COC #:** 1078068  
**Sample ID:** 1078068-4

## CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	2.6 ppb	0 to 15 ppb	Pass

**BDL** = Below detection limit; **cfu** = colony forming units; **mg/L** = milligrams per liter; **ntu** = nephelometric turbidity units  
**pH** = acidity/alkalinity units; **ppm** = parts per million; **ppb** = parts per billion; **µS/cm** = microSiemens per centimeter  
**U** = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.  
**DET** = Analyte detected; **ND** = Analyte not detected at or above the detection limit; **NR** = Not reported; **dry** = Sample results reported on a dry weight basis.  
**RPT** = Relative percent difference; **V** = Indicates that the analyte was detected in both the sample and the associated method blank.  
**I** = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.  
**Z** = too many colonies were present for accurate counting

**CONCLUSION: PASS**

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

**Test Address:**

GOLETA UNION SCHOOL DISTRICT  
5669 HOLLISTER AVE  
GOLETA, CA 93117

5465 QUEEN ANN LN  
SANTA BARBARA, CA 93111

Email: jwalker@goleta.k12.ca.us  
Phone: (805) 681-1231

Sample Date: October 5, 2017  
Date Received: October 11, 2017  
Analysis Date: October 16, 2017  
Report Date: October 16, 2017  
Sample Location: Room 1

Test / COC #: 1078068  
Sample ID: 1078068-5

## CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	2.0 ppb	0 to 15 ppb	Pass

BDL = Below detection limit; cfu = colony forming units; mg/L = milligrams per liter; ntu = nephelometric turbidity units  
 pH = acidity/alkalinity units; ppm = parts per million; ppb = parts per billion; µS/cm = microSiemens per centimeter  
 U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.  
 DET = Analyte detected; ND = Analyte not detected at or above the detection limit; NR = Not reported; dry = Sample results reported on a dry weight basis.  
 RPT = Relative percent difference; V = Indicates that the analyte was detected in both the sample and the associated method blank.  
 I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.  
 Z = too many colonies were present for accurate counting

**CONCLUSION: PASS**

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

  
 \_\_\_\_\_  
 Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

Test Address:

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

5465 QUEEN ANN LN
SANTA BARBARA, CA 93111

Email: jwalker@goleta.k12.ca.us
Phone: (805) 681-1231

Sample Date: October 5, 2017
Date Received: October 11, 2017
Analysis Date: October 16, 2017
Report Date: October 16, 2017
Sample Location: Room 2

Test / COC #: 1078068
Sample ID: 1078068-6

CERTIFICATE OF WATER ANALYSIS

Table with 4 columns: TEST ITEM, RESULT, ACCEPTABLE RANGE, DETERMINATION. Row 1: LEAD, 2.0 ppb, 0 to 15 ppb, Pass

BDL = Below detection limit; cfu = colony forming units; mg/L = milligrams per liter; ntu = nephelometric turbidity units
pH = acidity/alkalinity units; ppm = parts per million; ppb = parts per billion; uS/cm = microSiemens per centimeter
U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
DET = Analyte detected; ND = Analyte not detected at or above the detection limit; NR = Not reported; dry = Sample results reported on a dry weight basis.
RPT = Relative percent difference; V = Indicates that the analyte was detected in both the sample and the associated method blank.
I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: http://water.epa.gov/drink/contaminants/index.cfm

Handwritten signature of Carlos Ochoa

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

**Test Address:**

GOLETA UNION SCHOOL DISTRICT  
5669 HOLLISTER AVE  
GOLETA, CA 93117

5465 QUEEN ANN LN  
SANTA BARBARA, CA 93111

**Email:** jwalker@goleta.k12.ca.us  
**Phone:** (805) 681-1231

**Sample Date:** October 5, 2017  
**Date Received:** October 11, 2017  
**Analysis Date:** October 16, 2017  
**Report Date:** October 16, 2017  
**Sample Location:** Room 3

**Test / COC #:** 1078068  
**Sample ID:** 1078068-7

## CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	ND ppb	0 to 15 ppb	Pass

**BDL** = Below detection limit; **cfu** = colony forming units; **mg/L** = milligrams per liter; **ntu** = nephelometric turbidity units  
**pH** = acidity/alkalinity units; **ppm** = parts per million; **ppb** = parts per billion; **µS/cm** = microSiemens per centimeter  
**U** = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.  
**DET** = Analyte detected; **ND** = Analyte not detected at or above the detection limit; **NR** = Not reported; **dry** = Sample results reported on a dry weight basis.  
**RPT** = Relative percent difference; **V** = Indicates that the analyte was detected in both the sample and the associated method blank.  
**I** = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.  
**Z** = too many colonies were present for accurate counting

**CONCLUSION: PASS**

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

**Test Address:**

GOLETA UNION SCHOOL DISTRICT  
5669 HOLLISTER AVE  
GOLETA, CA 93117

5465 QUEEN ANN LN  
SANTA BARBARA, CA 93111

Email: jwalker@goleta.k12.ca.us  
Phone: (805) 681-1231

Sample Date: October 5, 2017  
Date Received: October 11, 2017  
Analysis Date: October 16, 2017  
Report Date: October 16, 2017  
Sample Location: Room 4

Test / COC #: 1078068  
Sample ID: 1078068-8

## CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	2.4 ppb	0 to 15 ppb	Pass

BDL = Below detection limit; cfu = colony forming units; mg/L = milligrams per liter; ntu = nephelometric turbidity units  
 pH = acidity/alkalinity units; ppm = parts per million; ppb = parts per billion; µS/cm = microSiemens per centimeter  
 U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.  
 DET = Analyte detected; ND = Analyte not detected at or above the detection limit; NR = Not reported; dry = Sample results reported on a dry weight basis.  
 RPT = Relative percent difference; V = Indicates that the analyte was detected in both the sample and the associated method blank.  
 I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.  
 Z = too many colonies were present for accurate counting

**CONCLUSION: PASS**

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager





1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

**Test Address:**

GOLETA UNION SCHOOL DISTRICT  
5669 HOLLISTER AVE  
GOLETA, CA 93117

5465 QUEEN ANN LN  
SANTA BARBARA, CA 93111

Email: jwalker@goleta.k12.ca.us  
Phone: (805) 681-1231

Sample Date: October 5, 2017  
Date Received: October 11, 2017  
Analysis Date: October 16, 2017  
Report Date: October 16, 2017  
Sample Location: Room 5

Test / COC #: 1078068  
Sample ID: 1078068-9

## CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	ND ppb	0 to 15 ppb	Pass

BDL = Below detection limit; cfu = colony forming units; mg/L = milligrams per liter; ntu = nephelometric turbidity units  
pH = acidity/alkalinity units; ppm = parts per million; ppb = parts per billion; µS/cm = microSiemens per centimeter  
U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.  
DET = Analyte detected; ND = Analyte not detected at or above the detection limit; NR = Not reported; dry = Sample results reported on a dry weight basis.  
RPT = Relative percent difference; V = Indicates that the analyte was detected in both the sample and the associated method blank.  
I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.  
Z = too many colonies were present for accurate counting

**CONCLUSION: PASS**

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

**Test Address:**

GOLETA UNION SCHOOL DISTRICT  
5669 HOLLISTER AVE  
GOLETA, CA 93117

5465 QUEEN ANN LN  
SANTA BARBARA, CA 93111

**Email:** jwalker@goleta.k12.ca.us  
**Phone:** (805) 681-1231

**Sample Date:** October 5, 2017  
**Date Received:** October 11, 2017  
**Analysis Date:** October 16, 2017  
**Report Date:** October 16, 2017  
**Sample Location:** Room 6

**Test / COC #:** 1078068  
**Sample ID:** 1078068-10

## CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	ND ppb	0 to 15 ppb	Pass

**BDL** = Below detection limit; **cfu** = colony forming units; **mg/L** = milligrams per liter; **ntu** = nephelometric turbidity units  
**pH** = acidity/alkalinity units; **ppm** = parts per million; **ppb** = parts per billion; **µS/cm** = microSiemens per centimeter  
**U** = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.  
**DET** = Analyte detected; **ND** = Analyte not detected at or above the detection limit; **NR** = Not reported; **dry** = Sample results reported on a dry weight basis.  
**RPT** = Relative percent difference; **V** = Indicates that the analyte was detected in both the sample and the associated method blank.  
**I** = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.  
**Z** = too many colonies were present for accurate counting

**CONCLUSION: PASS**

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



Test Address:

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

5465 QUEEN ANN LN
SANTA BARBARA, CA 93111

Email: jwalker@goleta.k12.ca.us
Phone: (805) 681-1231

Sample Date: October 5, 2017
Date Received: October 11, 2017
Analysis Date: October 16, 2017
Report Date: October 16, 2017
Sample Location: Room 7

Test / COC #: 1078068
Sample ID: 1078068-11

CERTIFICATE OF WATER ANALYSIS

Table with 4 columns: TEST ITEM, RESULT, ACCEPTABLE RANGE, DETERMINATION. Row 1: LEAD, 3.0 ppb, 0 to 15 ppb, Pass

BDL = Below detection limit; cfu = colony forming units; mg/L = milligrams per liter; ntu = nephelometric turbidity units
pH = acidity/alkalinity units; ppm = parts per million; ppb = parts per billion; uS/cm = microSiemens per centimeter
U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
DET = Analyte detected; ND = Analyte not detected at or above the detection limit; NR = Not reported; dry = Sample results reported on a dry weight basis.
RPT = Relative percent difference; V = Indicates that the analyte was detected in both the sample and the associated method blank.
I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: http://water.epa.gov/drink/contaminants/index.cfm

Handwritten signature of Carlos Ochoa

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

**Test Address:**

GOLETA UNION SCHOOL DISTRICT  
5669 HOLLISTER AVE  
GOLETA, CA 93117

5465 QUEEN ANN LN  
SANTA BARBARA, CA 93111

**Email:** jwalker@goleta.k12.ca.us  
**Phone:** (805) 681-1231

**Sample Date:** October 5, 2017  
**Date Received:** October 11, 2017  
**Analysis Date:** October 16, 2017  
**Report Date:** October 16, 2017  
**Sample Location:** Room 8

**Test / COC #:** 1078068  
**Sample ID:** 1078068-12

## CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	4.3 ppb	0 to 15 ppb	Pass

**BDL** = Below detection limit; **cfu** = colony forming units; **mg/L** = milligrams per liter; **ntu** = nephelometric turbidity units  
**pH** = acidity/alkalinity units; **ppm** = parts per million; **ppb** = parts per billion; **µS/cm** = microSiemens per centimeter  
**U** = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.  
**DET** = Analyte detected; **ND** = Analyte not detected at or above the detection limit; **NR** = Not reported; **dry** = Sample results reported on a dry weight basis.  
**RPT** = Relative percent difference; **V** = Indicates that the analyte was detected in both the sample and the associated method blank.  
**I** = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.  
**Z** = too many colonies were present for accurate counting

**CONCLUSION: PASS**

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

**Test Address:**

GOLETA UNION SCHOOL DISTRICT  
5669 HOLLISTER AVE  
GOLETA, CA 93117

5465 QUEEN ANN LN  
SANTA BARBARA, CA 93111

**Email:** jwalker@goleta.k12.ca.us  
**Phone:** (805) 681-1231

**Sample Date:** October 5, 2017  
**Date Received:** October 11, 2017  
**Analysis Date:** October 16, 2017  
**Report Date:** October 16, 2017  
**Sample Location:** Room 9

**Test / COC #:** 1078068  
**Sample ID:** 1078068-13

## CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	2.7 ppb	0 to 15 ppb	Pass

**BDL** = Below detection limit; **cfu** = colony forming units; **mg/L** = milligrams per liter; **ntu** = nephelometric turbidity units  
**pH** = acidity/alkalinity units; **ppm** = parts per million; **ppb** = parts per billion; **µS/cm** = microSiemens per centimeter  
**U** = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.  
**DET** = Analyte detected; **ND** = Analyte not detected at or above the detection limit; **NR** = Not reported; **dry** = Sample results reported on a dry weight basis.  
**RPT** = Relative percent difference; **V** = Indicates that the analyte was detected in both the sample and the associated method blank.  
**I** = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.  
**Z** = too many colonies were present for accurate counting

**CONCLUSION: PASS**

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

Test Address:

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

5465 QUEEN ANN LN
SANTA BARBARA, CA 93111

Email: jwalker@goleta.k12.ca.us
Phone: (805) 681-1231

Sample Date: October 5, 2017
Date Received: October 11, 2017
Analysis Date: October 16, 2017
Report Date: October 16, 2017
Sample Location: Room 10

Test / COC #: 1078068
Sample ID: 1078068-14

CERTIFICATE OF WATER ANALYSIS

Table with 4 columns: TEST ITEM, RESULT, ACCEPTABLE RANGE, DETERMINATION. Row 1: LEAD, ND ppb, 0 to 15 ppb, Pass

BDL = Below detection limit; cfu = colony forming units; mg/L = milligrams per liter; ntu = nephelometric turbidity units
pH = acidity/alkalinity units; ppm = parts per million; ppb = parts per billion; uS/cm = microSiemens per centimeter
U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
DET = Analyte detected; ND = Analyte not detected at or above the detection limit; NR = Not reported; dry = Sample results reported on a dry weight basis.
RPT = Relative percent difference; V = Indicates that the analyte was detected in both the sample and the associated method blank.
I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: http://water.epa.gov/drink/contaminants/index.cfm

Handwritten signature of Carlos Ochoa

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

**Test Address:**

GOLETA UNION SCHOOL DISTRICT  
5669 HOLLISTER AVE  
GOLETA, CA 93117

5465 QUEEN ANN LN  
SANTA BARBARA, CA 93111

**Email:** jwalker@goleta.k12.ca.us  
**Phone:** (805) 681-1231

**Sample Date:** October 5, 2017  
**Date Received:** October 11, 2017  
**Analysis Date:** October 16, 2017  
**Report Date:** October 16, 2017  
**Sample Location:** Room 11

**Test / COC #:** 1078068  
**Sample ID:** 1078068-15

## CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	ND ppb	0 to 15 ppb	Pass

BDL = Below detection limit; cfu = colony forming units; mg/L = milligrams per liter; ntu = nephelometric turbidity units  
pH = acidity/alkalinity units; ppm = parts per million; ppb = parts per billion; µS/cm = microSiemens per centimeter  
U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.  
DET = Analyte detected; ND = Analyte not detected at or above the detection limit; NR = Not reported; dry = Sample results reported on a dry weight basis.  
RPT = Relative percent difference; V = Indicates that the analyte was detected in both the sample and the associated method blank.  
I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.  
Z = too many colonies were present for accurate counting

**CONCLUSION: PASS**

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

**Test Address:**

GOLETA UNION SCHOOL DISTRICT  
5669 HOLLISTER AVE  
GOLETA, CA 93117

5465 QUEEN ANN LN  
SANTA BARBARA, CA 93111

Email: jwalker@goleta.k12.ca.us  
Phone: (805) 681-1231

Sample Date: October 5, 2017  
Date Received: October 11, 2017  
Analysis Date: October 16, 2017  
Report Date: October 16, 2017  
Sample Location: Room 12

Test / COC #: 1078068  
Sample ID: 1078068-16

## CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	2.5 ppb	0 to 15 ppb	Pass

BDL = Below detection limit; cfu = colony forming units; mg/L = milligrams per liter; ntu = nephelometric turbidity units  
 pH = acidity/alkalinity units; ppm = parts per million; ppb = parts per billion; µS/cm = microSiemens per centimeter  
 U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.  
 DET = Analyte detected; ND = Analyte not detected at or above the detection limit; NR = Not reported; dry = Sample results reported on a dry weight basis.  
 RPT = Relative percent difference; V = Indicates that the analyte was detected in both the sample and the associated method blank.  
 I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.  
 Z = too many colonies were present for accurate counting

**CONCLUSION: PASS**

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager





1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

Test Address:

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

5465 QUEEN ANN LN
SANTA BARBARA, CA 93111

Email: jwalker@goleta.k12.ca.us
Phone: (805) 681-1231

Sample Date: October 5, 2017
Date Received: October 11, 2017
Analysis Date: October 16, 2017
Report Date: October 16, 2017
Sample Location: Room 13

Test / COC #: 1078068
Sample ID: 1078068-17

CERTIFICATE OF WATER ANALYSIS

Table with 4 columns: TEST ITEM, RESULT, ACCEPTABLE RANGE, DETERMINATION. Row 1: LEAD, 1.9 ppb, 0 to 15 ppb, Pass

BDL = Below detection limit; cfu = colony forming units; mg/L = milligrams per liter; ntu = nephelometric turbidity units
pH = acidity/alkalinity units; ppm = parts per million; ppb = parts per billion; uS/cm = microSiemens per centimeter
U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
DET = Analyte detected; ND = Analyte not detected at or above the detection limit; NR = Not reported; dry = Sample results reported on a dry weight basis.
RPT = Relative percent difference; V = Indicates that the analyte was detected in both the sample and the associated method blank.
I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: http://water.epa.gov/drink/contaminants/index.cfm

Handwritten signature of Carlos Ochoa
Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

**Test Address:**

GOLETA UNION SCHOOL DISTRICT  
5669 HOLLISTER AVE  
GOLETA, CA 93117

5465 QUEEN ANN LN  
SANTA BARBARA, CA 93111

Email: jwalker@goleta.k12.ca.us  
Phone: (805) 681-1231

Sample Date: October 5, 2017  
Date Received: October 11, 2017  
Analysis Date: October 16, 2017  
Report Date: October 16, 2017  
Sample Location: Room 14

Test / COC #: 1078068  
Sample ID: 1078068-18

## CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	3.1 ppb	0 to 15 ppb	Pass

BDL = Below detection limit; cfu = colony forming units; mg/L = milligrams per liter; ntu = nephelometric turbidity units  
 pH = acidity/alkalinity units; ppm = parts per million; ppb = parts per billion; µS/cm = microSiemens per centimeter  
 U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.  
 DET = Analyte detected; ND = Analyte not detected at or above the detection limit; NR = Not reported; dry = Sample results reported on a dry weight basis.  
 RPT = Relative percent difference; V = Indicates that the analyte was detected in both the sample and the associated method blank.  
 I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.  
 Z = too many colonies were present for accurate counting

**CONCLUSION: PASS**

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

Test Address:

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

5465 QUEEN ANN LN
SANTA BARBARA, CA 93111

Email: jwalker@goleta.k12.ca.us
Phone: (805) 681-1231

Sample Date: October 5, 2017
Date Received: October 11, 2017
Analysis Date: October 16, 2017
Report Date: October 16, 2017
Sample Location: Room 15

Test / COC #: 1078068
Sample ID: 1078068-19

CERTIFICATE OF WATER ANALYSIS

Table with 4 columns: TEST ITEM, RESULT, ACCEPTABLE RANGE, DETERMINATION. Row 1: LEAD, 2.7 ppb, 0 to 15 ppb, Pass

BDL = Below detection limit; cfu = colony forming units; mg/L = milligrams per liter; ntu = nephelometric turbidity units
pH = acidity/alkalinity units; ppm = parts per million; ppb = parts per billion; uS/cm = microSiemens per centimeter
U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
DET = Analyte detected; ND = Analyte not detected at or above the detection limit; NR = Not reported; dry = Sample results reported on a dry weight basis.
RPT = Relative percent difference; V = Indicates that the analyte was detected in both the sample and the associated method blank.
I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: http://water.epa.gov/drink/contaminants/index.cfm

Handwritten signature of Carlos Ochoa

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

**Test Address:**

GOLETA UNION SCHOOL DISTRICT  
5669 HOLLISTER AVE  
GOLETA, CA 93117

5465 QUEEN ANN LN  
SANTA BARBARA, CA 93111

**Email:** jwalker@goleta.k12.ca.us  
**Phone:** (805) 681-1231

**Sample Date:** October 5, 2017  
**Date Received:** October 11, 2017  
**Analysis Date:** October 16, 2017  
**Report Date:** October 16, 2017  
**Sample Location:** Room 16

**Test / COC #:** 1078068  
**Sample ID:** 1078068-20

## CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	1.8 ppb	0 to 15 ppb	Pass

**BDL** = Below detection limit; **cfu** = colony forming units; **mg/L** = milligrams per liter; **ntu** = nephelometric turbidity units  
**pH** = acidity/alkalinity units; **ppm** = parts per million; **ppb** = parts per billion; **µS/cm** = microSiemens per centimeter  
**U** = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.  
**DET** = Analyte detected; **ND** = Analyte not detected at or above the detection limit; **NR** = Not reported; **dry** = Sample results reported on a dry weight basis.  
**RPT** = Relative percent difference; **V** = Indicates that the analyte was detected in both the sample and the associated method blank.  
**I** = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.  
**Z** = too many colonies were present for accurate counting

**CONCLUSION: PASS**

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

**Test Address:**

GOLETA UNION SCHOOL DISTRICT  
5669 HOLLISTER AVE  
GOLETA, CA 93117

5465 QUEEN ANN LN  
SANTA BARBARA, CA 93111

**Email:** jwalker@goleta.k12.ca.us  
**Phone:** (805) 681-1231

**Sample Date:** October 5, 2017  
**Date Received:** October 11, 2017  
**Analysis Date:** October 16, 2017  
**Report Date:** October 16, 2017  
**Sample Location:** Room 17

**Test / COC #:** 1078068  
**Sample ID:** 1078068-21

## CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	ND ppb	0 to 15 ppb	Pass

BDL = Below detection limit; cfu = colony forming units; mg/L = milligrams per liter; ntu = nephelometric turbidity units  
 pH = acidity/alkalinity units; ppm = parts per million; ppb = parts per billion; µS/cm = microSiemens per centimeter  
 U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.  
 DET = Analyte detected; ND = Analyte not detected at or above the detection limit; NR = Not reported; dry = Sample results reported on a dry weight basis.  
 RPT = Relative percent difference; V = Indicates that the analyte was detected in both the sample and the associated method blank.  
 I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.  
 Z = too many colonies were present for accurate counting

**CONCLUSION: PASS**

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

**Test Address:**

GOLETA UNION SCHOOL DISTRICT  
5669 HOLLISTER AVE  
GOLETA, CA 93117

5465 QUEEN ANN LN  
SANTA BARBARA, CA 93111

**Email:** jwalker@goleta.k12.ca.us  
**Phone:** (805) 681-1231

**Sample Date:** October 5, 2017  
**Date Received:** October 11, 2017  
**Analysis Date:** October 16, 2017  
**Report Date:** October 16, 2017  
**Sample Location:** Room 18

**Test / COC #:** 1078068  
**Sample ID:** 1078068-22

## CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	1.8 ppb	0 to 15 ppb	Pass

**BDL** = Below detection limit; **cfu** = colony forming units; **mg/L** = milligrams per liter; **ntu** = nephelometric turbidity units  
**pH** = acidity/alkalinity units; **ppm** = parts per million; **ppb** = parts per billion; **µS/cm** = microSiemens per centimeter  
**U** = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.  
**DET** = Analyte detected; **ND** = Analyte not detected at or above the detection limit; **NR** = Not reported; **dry** = Sample results reported on a dry weight basis.  
**RPT** = Relative percent difference; **V** = Indicates that the analyte was detected in both the sample and the associated method blank.  
**I** = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.  
**Z** = too many colonies were present for accurate counting

**CONCLUSION: PASS**

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

Test Address:

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

5465 QUEEN ANN LN
SANTA BARBARA, CA 93111

Email: jwalker@goleta.k12.ca.us
Phone: (805) 681-1231

Sample Date: October 5, 2017
Date Received: October 11, 2017
Analysis Date: October 16, 2017
Report Date: October 16, 2017
Sample Location: Room 19

Test / COC #: 1078068
Sample ID: 1078068-23

CERTIFICATE OF WATER ANALYSIS

Table with 4 columns: TEST ITEM, RESULT, ACCEPTABLE RANGE, DETERMINATION. Row 1: LEAD, 3.3 ppb, 0 to 15 ppb, Pass

BDL = Below detection limit; cfu = colony forming units; mg/L = milligrams per liter; ntu = nephelometric turbidity units
pH = acidity/alkalinity units; ppm = parts per million; ppb = parts per billion; uS/cm = microSiemens per centimeter
U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
DET = Analyte detected; ND = Analyte not detected at or above the detection limit; NR = Not reported; dry = Sample results reported on a dry weight basis.
RPT = Relative percent difference; V = Indicates that the analyte was detected in both the sample and the associated method blank.
I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: http://water.epa.gov/drink/contaminants/index.cfm

Handwritten signature of Carlos Ochoa

Carlos Ochoa, Quality Control Manager



**Test Address:**

GOLETA UNION SCHOOL DISTRICT  
5669 HOLLISTER AVE  
GOLETA, CA 93117

5465 QUEEN ANN LN  
SANTA BARBARA, CA 93111

**Email:** jwalker@goleta.k12.ca.us  
**Phone:** (805) 681-1231

**Sample Date:** October 5, 2017  
**Date Received:** October 11, 2017  
**Analysis Date:** October 16, 2017  
**Report Date:** October 16, 2017  
**Sample Location:** Room Nurse's Sink

**Test / COC #:** 1078068  
**Sample ID:** 1078068-24

## CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	4.0 ppb	0 to 15 ppb	Pass

**BDL** = Below detection limit; **cfu** = colony forming units; **mg/L** = milligrams per liter; **ntu** = nephelometric turbidity units  
**pH** = acidity/alkalinity units; **ppm** = parts per million; **ppb** = parts per billion; **µS/cm** = microSiemens per centimeter  
**U** = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.  
**DET** = Analyte detected; **ND** = Analyte not detected at or above the detection limit; **NR** = Not reported; **dry** = Sample results reported on a dry weight basis.  
**RPT** = Relative percent difference; **V** = Indicates that the analyte was detected in both the sample and the associated method blank.  
**I** = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.  
**Z** = too many colonies were present for accurate counting

**CONCLUSION: PASS**

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager





1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

**Test Address:**

GOLETA UNION SCHOOL DISTRICT  
5669 HOLLISTER AVE  
GOLETA, CA 93117

5465 QUEEN ANN LN  
SANTA BARBARA, CA 93111

**Email:** jwalker@goleta.k12.ca.us  
**Phone:** (805) 681-1231

**Sample Date:** October 5, 2017  
**Date Received:** October 11, 2017  
**Analysis Date:** October 16, 2017  
**Report Date:** October 16, 2017  
**Sample Location:** Ka-outside Fountain

**Test / COC #:** 1078068  
**Sample ID:** 1078068-25

## CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	2.6 ppb	0 to 15 ppb	Pass

**BDL** = Below detection limit; **cfu** = colony forming units; **mg/L** = milligrams per liter; **ntu** = nephelometric turbidity units  
**pH** = acidity/alkalinity units; **ppm** = parts per million; **ppb** = parts per billion; **µS/cm** = microSiemens per centimeter  
**U** = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.  
**DET** = Analyte detected; **ND** = Analyte not detected at or above the detection limit; **NR** = Not reported; **dry** = Sample results reported on a dry weight basis.  
**RPT** = Relative percent difference; **V** = Indicates that the analyte was detected in both the sample and the associated method blank.  
**I** = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.  
**Z** = too many colonies were present for accurate counting

**CONCLUSION: PASS**

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

**Test Address:**

GOLETA UNION SCHOOL DISTRICT  
5669 HOLLISTER AVE  
GOLETA, CA 93117

5465 QUEEN ANN LN  
SANTA BARBARA, CA 93111

**Email:** jwalker@goleta.k12.ca.us  
**Phone:** (805) 681-1231

**Sample Date:** October 5, 2017  
**Date Received:** October 11, 2017  
**Analysis Date:** October 16, 2017  
**Report Date:** October 16, 2017  
**Sample Location:** Kb-outside Fountain

**Test / COC #:** 1078068  
**Sample ID:** 1078068-26

## CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	5.2 ppb	0 to 15 ppb	Pass

**BDL** = Below detection limit; **cfu** = colony forming units; **mg/L** = milligrams per liter; **ntu** = nephelometric turbidity units  
**pH** = acidity/alkalinity units; **ppm** = parts per million; **ppb** = parts per billion; **µS/cm** = microSiemens per centimeter  
**U** = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.  
**DET** = Analyte detected; **ND** = Analyte not detected at or above the detection limit; **NR** = Not reported; **dry** = Sample results reported on a dry weight basis.  
**RPT** = Relative percent difference; **V** = Indicates that the analyte was detected in both the sample and the associated method blank.  
**I** = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.  
**Z** = too many colonies were present for accurate counting

**CONCLUSION: PASS**

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

**Test Address:**

GOLETA UNION SCHOOL DISTRICT  
5669 HOLLISTER AVE  
GOLETA, CA 93117

5465 QUEEN ANN LN  
SANTA BARBARA, CA 93111

**Email:** jwalker@goleta.k12.ca.us  
**Phone:** (805) 681-1231

**Sample Date:** October 5, 2017  
**Date Received:** October 11, 2017  
**Analysis Date:** October 16, 2017  
**Report Date:** October 16, 2017  
**Sample Location:** Mpr-outside Fountain

**Test / COC #:** 1078068  
**Sample ID:** 1078068-27

## CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	ND ppb	0 to 15 ppb	Pass

BDL = Below detection limit; cfu = colony forming units; mg/L = milligrams per liter; ntu = nephelometric turbidity units  
 pH = acidity/alkalinity units; ppm = parts per million; ppb = parts per billion; µS/cm = microSiemens per centimeter  
 U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.  
 DET = Analyte detected; ND = Analyte not detected at or above the detection limit; NR = Not reported; dry = Sample results reported on a dry weight basis.  
 RPT = Relative percent difference; V = Indicates that the analyte was detected in both the sample and the associated method blank.  
 I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.  
 Z = too many colonies were present for accurate counting

**CONCLUSION: PASS**

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

**Test Address:**

GOLETA UNION SCHOOL DISTRICT  
5669 HOLLISTER AVE  
GOLETA, CA 93117

5465 QUEEN ANN LN  
SANTA BARBARA, CA 93111

Email: jwalker@goleta.k12.ca.us  
Phone: (805) 681-1231

Sample Date: October 5, 2017  
Date Received: October 11, 2017  
Analysis Date: October 16, 2017  
Report Date: October 16, 2017  
Sample Location: Lower-outside Fountain

Test / COC #: 1078068  
Sample ID: 1078068-28

## CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	ND ppb	0 to 15 ppb	Pass

BDL = Below detection limit; cfu = colony forming units; mg/L = milligrams per liter; ntu = nephelometric turbidity units  
 pH = acidity/alkalinity units; ppm = parts per million; ppb = parts per billion; µS/cm = microSiemens per centimeter  
 U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.  
 DET = Analyte detected; ND = Analyte not detected at or above the detection limit; NR = Not reported; dry = Sample results reported on a dry weight basis.  
 RPT = Relative percent difference; V = Indicates that the analyte was detected in both the sample and the associated method blank.  
 I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.  
 Z = too many colonies were present for accurate counting

**CONCLUSION: PASS**

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

Test Address:

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

5465 QUEEN ANN LN
SANTA BARBARA, CA 93111

Email: jwalker@goleta.k12.ca.us
Phone: (805) 681-1231

Sample Date: October 5, 2017
Date Received: October 11, 2017
Analysis Date: October 16, 2017
Report Date: October 16, 2017
Sample Location: Upper-outside Fountain

Test / COC #: 1078068
Sample ID: 1078068-29

CERTIFICATE OF WATER ANALYSIS

Table with 4 columns: TEST ITEM, RESULT, ACCEPTABLE RANGE, DETERMINATION. Row 1: LEAD, ND ppb, 0 to 15 ppb, Pass

BDL = Below detection limit; cfu = colony forming units; mg/L = milligrams per liter; ntu = nephelometric turbidity units
pH = acidity/alkalinity units; ppm = parts per million; ppb = parts per billion; uS/cm = microSiemens per centimeter
U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
DET = Analyte detected; ND = Analyte not detected at or above the detection limit; NR = Not reported; dry = Sample results reported on a dry weight basis.
RPT = Relative percent difference; V = Indicates that the analyte was detected in both the sample and the associated method blank.
I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: http://water.epa.gov/drink/contaminants/index.cfm

Handwritten signature of Carlos Ochoa

Carlos Ochoa, Quality Control Manager